

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0328:0192 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** Potter Electric Signal Co1609 Park 370 Place, Hazelwood, 63042 United States  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: BillW@pottersignal.com

**DESIGN:** Model RCDS-1 and Abort Switch. Both devices are accessories for releasing panels.

**RATING:** 24 VDC, 2.5 Amps.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Depending on applications, the authority having jurisdiction should be consulted prior to insulation.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as miscellaneous control accessories for use with listee's separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation.

06-02-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **November 08, 2017**

*Listing Expires* **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
*Fire Engineering Division*