

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-2078:0101

Page 1 of 1

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** Minimax USA, LLC 3025 Independence Dr. Suite C, Livermore, CA 94551  
Contact: Doug Meyers (480) 553-5670 Ext: 2769 Fax (480) 553-5701  
Email: dmeyers@minimaxfp.com

**DESIGN:** Model MX-2002 conventional fire alarm control unit. Each unit employs six programmable input circuits, four programmable output circuits, and three relay contact outputs for alarm, trouble, and supervisory signals. These units do not contain an integral digital alarm communicator transmitter (DACT). Model is intended for agent release control.

FLPS-7	Power Supply module
4XTMF	Transmitter module
CAC-5X	Converter module
ANN-80	LCD Annunciator
ANN-I / O	LED Driver module
ANN-LED	Annunciator module
ANN-RLY	Relay module
ANN-S / PG	Serial/Parallel printer module
DP-51050	Dress panel
DP-51050LED	Dress panel

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation, electrical rating and UL label.

**APPROVAL:** Listed as a fire alarm control unit suitable for use as agent releasing panel. Unit also provides fire detection, signaling and protection features. Refer to manufacturer's Installation Manual for details. This control unit meets the requirements of UL-864, 9th Edition Standards.

**XLF:** 7165-0075:0216

10-04-2011 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*